



Kansas Health & Environmental Laboratories
6810 SE Dwight Street
Topeka, KS 66620
Phone (785) 296-1620
Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
Larned State Hospital
1301 KS HWY 264
Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801116

Lab ID: 2306603
Sample ID: 5820-9
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Issac Ray Kitchen
Date Collected: 07/18/2022 08:45
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	1800	ug/L	2.0	2		07/22/2022 12:18	CW	08/01/2022 13:52	TAR		1300
Lead	1.1	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 18:23	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801108

Lab ID: 2306605
Sample ID: 5820
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Resident 203
Date Collected: 07/18/2022 08:00
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	4.5	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 18:41	DET		1300
Lead	1.1	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 18:41	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Raymond Keenan
Collection ID/Chain#: KIT801117

Lab ID: 2306604
Sample ID: 5820-10
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Dillon Kitchen
Date Collected: 07/18/2022 08:15
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
<i>METALS 200.8 (Metals Digestion/EPA 200.8)</i>											
Copper	730	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 18:27	DET		1300
Lead	<1.0	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 18:27	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801110

Lab ID: 2306597
Sample ID: 5820-3
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Admin BLDG
Date Collected: 07/18/2022 09:10
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	27	ug/L	1.0	1		07/28/2022 09:40	CW	08/01/2022 13:16	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/28/2022 09:40	CW	07/26/2022 17:48	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801112

Lab ID: 2306599
Sample ID: 5820-5
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Hospital BLDG
Date Collected: 07/18/2022 08:10
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	440	ug/L	1.0	1		07/28/2022 09:40	CW	08/01/2022 13:25	TAR		1300
Lead	3.9	ug/L	1.0	1		07/28/2022 09:40	CW	07/26/2022 17:57	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801109

Lab ID: 2306596
Sample ID: 5820-2
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Main Cafeteria
Date Collected: 07/18/2022 09:00
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
<i>METALS 200.8 (Metals Digestion/EPA 200.8)</i>											
Copper	1300	ug/L	1.0	1		07/22/2022 12:18	CW	08/01/2022 13:12	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/22/2022 12:18	CW	07/26/2022 17:43	DET		15



Kansas Health & Environmental Laboratories
6810 SE Dwight Street
Topeka, KS 66620
Phone (785) 296-1620
Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
Larned State Hospital
1301 KS HWY 264
Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801115

Lab ID: 2306602
Sample ID: 5820-8
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Suppy
Date Collected: 07/18/2022 08:35
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	440	ug/L	1.0	1		07/28/2022 09:41	CW	08/01/2022 13:38	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/28/2022 09:41	CW	07/26/2022 18:10	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801111

Lab ID: 2306598
Sample ID: 5820-4
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: ATC North
Date Collected: 07/18/2022 09:40
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	260	ug/L	1.0	1		07/28/2022 09:40	CW	08/01/2022 13:21	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/28/2022 09:40	CW	07/26/2022 17:52	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801114

Lab ID: 2306601
Sample ID: 5820-7
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: LCMHF MAINT
Date Collected: 07/18/2022 08:20
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	370	ug/L	1.0	1		07/28/2022 09:41	CW	08/01/2022 13:34	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/28/2022 09:41	CW	07/26/2022 18:05	DET		15



Kansas Health & Environmental Laboratories
 6810 SE Dwight Street
 Topeka, KS 66620
 Phone (785) 296-1620
 Fax (785) 559-5205

Analytical Results

FINAL

Submitter: Larned State Hospital
Report To: Kevin Greathouse
 Larned State Hospital
 1301 KS HWY 264
 Larned, KS 67550

Client ID: KS2014503
State ID: N0529
Collector: Ramon Keenan
Collection ID/Chain#: KIT801113

Lab ID: 2306600
Sample ID: 5820-6
Description: DS1 DISTRIBUTION
Matrix: Drinking Water

Location Description: Daycare
Date Collected: 07/18/2022 09:25
Date Received: 07/19/2022 09:29

Parameter	Results	Units	RDL	DF	Unc.	Prepared	By	Analyzed	By	Qual	RegLmt
METALS 200.8 (Metals Digestion/EPA 200.8)											
Copper	43	ug/L	1.0	1		07/28/2022 09:40	CW	08/01/2022 13:30	TAR		1300
Lead	<1.0	ug/L	1.0	1		07/28/2022 09:40	CW	07/26/2022 18:01	DET		15